



**Thermal Imaging Survey
Conducted at
1072 High Road London N20 0QP**

Water Leak



3th April 2008

**By
LeakBusters
Engineer
David Farmer**



LEAKBUSTERS TEL: 0800 328 8125

Water Leak at 1072 High Road London N20 0QP



IR information	Value
Time of creation	08:25:48
Object parameter	Value
Atmospheric temperature	21.0°C
Label	Value
LI01 : max	21.8°C

IR information	Value
Time of creation	09:00:05
Object parameter	Value
Atmospheric temperature	21.0°C
Label	Value
LI01 : max	22.6°C

IR information	Value
Time of creation	09:02:56
Object parameter	Value
Atmospheric temperature	21.0°C
Label	Value
LI01 : max	23.6°C

IR information	Value
Time of creation	09:31:33
Object parameter	Value
Atmospheric temperature	21.0°C
Label	Value
LI01 : max	24.2°C

The 4 images above show how the thermal patterns are increasing over a period of a hour, this indicates that a water leak may be present in this area.